

ORDINANCE NUMBER 239

**AN ORDINANCE REPEALING ORDINANCE NUMBER 204 AND ADOPTING
THE 2021 EDITION OF THE *INTERNATIONAL BUILDING CODE*,
WITH AMENDMENTS, IN THE WOODSTOCK FIRE/RESCUE DISTRICT,
McHENRY COUNTY, ILLINOIS**

WHEREAS, pursuant to Section 11 of the Fire Protection District Act, the Woodstock Fire/Rescue District (the “District”) Board of Trustees may prescribe necessary regulations for the prevention and control of fire;

WHEREAS, the District previously passed Ordinance Number 204 relating to adopting the 2015 Edition of the International Building Code and the 2015 Edition of the International Swimming Pool and Spa Code, with amendments, in the District;

WHEREAS, the Districts wishes to update and adopt the 2021 Edition of the International Building Code and the 2021 International Residential Code; and

WHEREAS, the adoption of these Codes are of benefit to the District, its visitors, occupants, and owners.

NOW, THEREFORE, BE IT ORDAINED BY THE BOARD OF TRUSTEES OF THE WOODSTOCK FIRE/RESCUE DISTRICT, THAT:

SECTION 1: Repeal of Ordinance Number 204. Ordinance Number 204 relating to adopting the 2015 Edition of the International Building Code and the 2015 Edition of the International Swimming Pool and Spa Code, with amendments, in the District is hereby repealed in its entirety.

SECTION 2: Adoption of International Building Code. The International Building Code, 2021 Edition, is hereby adopted as the building code for the District, for the control of buildings and structures as herein provided, except for those buildings and structures used exclusively as one-family and two-family dwelling units, and each and all of the regulations, provisions, penalties, conditions and terms of said International Building Code, are hereby referred to, adopted and made a part hereof as if fully set out in this section, with additions, insertions, deletions, and changes prescribed in Section 3. All other ordinances or parts of ordinances in conflict herewith are hereby repealed to the extent of such conflict.

SECTION 3: Additions, Insertions, and Changes. The following sections of the International Building Code, 2021 Edition, are hereby revised as follows:

General - Section [A] 101.1 Title.

Insert: “Woodstock Fire/Rescue District, McHenry County, Illinois”.

General - Section [A] 101.4.3 Plumbing.

Delete: "...International Plumbing...".

Insert: "...Illinois State Plumbing Code, current edition...".

General - Section [A] 101.4.6 Energy.

Delete: "...International Energy Conservation Code..."

Insert: "...Illinois Energy Conservation Code, current edition..."

General - Section [A] 103.1 Creation of Enforcement Agency.

Insert: "...Woodstock Fire/Rescue District..."

Duties and Powers of Building Official - Section [A] 104.1 General.

Insert at end: "The Building Official, however, is authorized to approve minor building alterations, improvements, or changes after making a determination that such alterations, improvements, or changes do not affect the safety or structural integrity of a building or structure or negate the intent of these regulations. The Building Official is hereby authorized to enforce the provisions of this code within the boundaries of the Woodstock Fire/Rescue District, except in municipalities in which fire prevention codes have been adopted."

Submittal Documents - Section [A] 107.1 General.

Delete: "...two or more sets with each permit application".

Insert: "...three or more hard copy (paper) sets and one digital/electronic set with each permit application."

Certificate of Occupancy - Section [A] 111.1 Change of Occupancy.

Insert at end: "A change of use or occupancy inspection is required for all existing buildings where a change of IBC use and/or occupancy occurs. This change of use and occupancy inspection may or may not include associated alterations. This inspection is not combined with other permit processes such as New Construction and Additions."

Certificate of Occupancy – Section [A] 111.1.2 Change of Use.

Insert: "111.1.2 Change of Use. Before issuing a change of use certificate of occupancy, the building official is authorized to examine or cause to be examined buildings, structures and sites for which a Change of Occupancy application has been filed. It shall be the duty of the owner or the owner's authorized agent to allow for the access of the buildings, structures and sites for inspection purposes. Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of this code or of other

ordinances of the jurisdiction. Inspections presuming to give authority to violate or cancel the provisions of this code or of other ordinances of the jurisdiction shall not be valid. Neither the building official nor the jurisdiction shall be liable for the expense entailed in the removal or replacement of any material required to allow inspections.”

Certificate of Occupancy - Section [A] 111.1.3 Required Inspections.

Insert: “111.1.3 Required Inspections. The purpose of this inspection is to establish minimum requirements to provide a reasonable level of health, safety, property protection and general welfare insofar as they are affected by the continued occupancy and maintenance of structures and premises. Existing structures and premises that do not comply with the provisions of the International Property Maintenance Code as adopted, shall be altered or repaired to provide a reasonable minimum level of health, safety and general welfare as required therein.”

Board of Appeals - Section [A] 113 Board of Appeals.

Delete: Sections 113.1 through 113.3.

Insert: “113.1 Board of Appeals Established. Any person shall have the right to appeal to appeal a decision of the application and interpretation of this code by the Building Official. Appeals will be heard by the Woodstock Fire/Rescue District Board of Trustees. An application for appeal shall be based on a claim that the true intent of this code or the rules legally adopted thereunder have been incorrectly interpreted, the provisions of this code do not fully apply, or an equivalent form of construction can be used.

The establishment of the Woodstock Fire/Rescue District Board of Trustees, its membership and their terms, frequency of meetings, and the powers and duties shall be as indicated in Illinois statutes and any ordinances of the Woodstock Fire/Rescue District.”

Violations - Section [A] 114.4 Violation Penalties.

Delete: “...subject to penalties as prescribed by law.”

Insert: “...shall be guilty of an ordinance violation, punishable by a fine of not less than \$250.00 or double the permit fee, whichever is greater, and be responsible for the Woodstock Fire/Rescue District’s cost of prosecution, including, but not limited to, filing fees, witness fees, and attorneys’ fees. Each day that a violation exists shall constitute a separate offense.”

Definitions - Section 202 [BG] High-Rise Buildings.

Delete: “...75 feet...”.

Insert: “...50 feet...”.

Fire Partitions - Section 708.1 General.

Item 1.: Insert: “Walls separating dwelling units, and separate tenants or businesses, in the same building.”

Fire Partitions - Section 708.3 Fire-Resistance Rating.

Delete: Exception 2.

Floor and Roof Assemblies - Section 711.2.4.3 Dwelling Units and Sleeping Units.

Delete: Exception.

Automatic Sprinkler Systems - Section 903.1 General.

Delete: First paragraph.

Insert: “Automatic sprinkler systems shall comply with this section. New construction activity (excluding the remodeling or alteration of existing buildings and structures and not involving a change in use) for all use groups having a fire area exceeding five thousand (5,000) or more square feet shall be required to install an automatic sprinkler system, except as follows:

When additions are made to an existing building or structure having an existing fire area of five thousand (5,000) square feet or less, and when such additions result in the building or structure having an aggregate fire area of seventy-five hundred (7,500) or more square feet, an automatic sprinkler system is required and shall be provided.”

Automatic Sprinkler Systems - Section 903.2.1.1 Group A-1.

Subsection 1: Delete: Current section verbiage.

Insert: “Where a single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”

Automatic Sprinkler Systems - Section 903.2.1.2 Group A-2.

Subsection 1: Delete: Current section verbiage.

Insert: “Where a single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”

Automatic Sprinkler Systems - Section 903.2.1.3 Group A-3.

Subsection 1: Delete: Current section verbiage.

Insert: “Where a single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”

Automatic Sprinkler Systems - Section 903.2.1.4 Group A-4.

Subsection 1: Delete: Current section verbiage.

Insert: “Where a single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”

Automatic Sprinkler Systems - Section 903.2.3 Group E.

Subsection 1: Delete: Current section verbiage.

Insert: “Where a single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”

Delete: Exception

Automatic Sprinkler Systems - Section 903.2.4 Group F-1 and F-2.

Insert: “903.2.4 Groups F-1 and F-2”.

Insert: “...containing a group F-1 or F-2 occupancy ...”.

Item 1.: Revise to read: “Where a group F-1 or F-2 single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”

Item 2.: Revise to read: “Where a group F-1 or F-2 fire area is located more than two stories above grade plane.”

Item 3.: Delete.

Insert: “Exception: One-story, group F-2 buildings meeting the requirements of section 507.3.”

Automatic Sprinkler Systems - Section 903.2.7 Group B or M.

Insert: “903.2.7 Groups B or M”.

Insert: “a group B or M...”.

- Item 1.: Revise to read: “Where a group B or M single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet.”
- Item 2.: Revise to read: “here a group B or M fire area is located more than two stories above grade plane.”
- Item 3.: Delete.

Automatic Sprinkler Systems - Section 903.2.9 Group S-1 and S-2.

Insert: “903.2.9 Groups S-1 and S-2”

Insert: “...a group S-1 or S-2...occupancy”.

- Item 1.: Revise to read: “here a group S-1 or S-2 single fire area, aggregate of all fire areas, or where the aggregate area of a building or structure separated by a fire wall or fire walls, exceeds 5,000 square feet including any mezzanines.”
- Item 2.: Revise to read: “here a group S-1 or S-2 fire area is located more than two stories above grade plane.”
- Item 3.: Delete.
Insert: “Exception: One-story, group S-2 buildings meeting the requirements of section 507.3.”

Automatic Sprinkler Systems - Section 903.2.9.1 Repair Garages.

- Item 1.: Delete: “... 10,000...”.
Insert: “...5,000...”.
- Item 2.: Delete: “... 12,000 ...”.
Insert: “...5,000...”.

Automatic Sprinkler Systems - Section 903.2.10 Parking Garages.

Rename section title: Delete: “Group S-2”.

Automatic Sprinkler Systems - Section 903.2.11.3 Buildings 50 Feet or More in Height.

Rename section title: Delete: “55 feet”.
Insert: “50 feet”.

Delete: "...55 feet...".

Insert: "...50 feet...".

Automatic Sprinkler Systems - Section 903.3.1.1.1 Exempt Locations.

Delete: Exception 4.

Automatic Sprinkler Systems - 903.3.5 Water Supplies.

Insert: "903.3.5.3 Hydraulic Design Safety Factor. All new sprinkler system designs shall include a safety factor of 5 pounds above the required operating pressure of any calculated system."

Automatic Sprinkler Systems - Section 903.4.1 Monitoring.

Delete: "...an approved supervising station...or proprietary supervising station ..." or, when approved by the fire code official, shall sound an audible signal at a constantly attended location.

Insert: "...a remote supervising station at the Woodstock police department, via the Woodstock Fire/Rescue District's radio network...".

Automatic Sprinkler Systems - Section 903.4.2 Alarms.

Delete: Current section verbiage.

Insert: "Approved audible and visual alarm appliances in the form of an approved 10-inch exterior bell and a white/clear, 75 cd, weatherproof strobe light shall be provided on the exterior of the building above the fire department sprinkler or standpipe connection; and, an approved 6-inch interior bell and a white 75 cd strobe light shall be provided within the building immediately outside of the sprinkler riser room when one is present or in a location approved by the fire department. These appliances shall only activate with the activation of a water-flow alarm device which shall be activated within 90-seconds by water flow equivalent to the flow of a single sprinkler of the smallest orifice size in the system. Where a fire alarm system is installed, actuation of the automatic fire sprinkler system shall actuate the building fire alarm system."

Automatic Sprinkler Systems - Section 903.4.3 Floor Control Valves.

Delete: Current section verbiage.

Insert: "Approved water-flow alarm devices and approved supervised indicating control valves shall be provided at the point of connection to the riser on each floor of the building."

Automatic Sprinkler Systems - Section 903.6 Room Identification and Lighting.

Insert: “903.6 General. All doors providing access to fire sprinkler riser control valves rooms and the main fire alarm control panel room shall be labeled in accordance with section F 510.1 (as amended) of the international fire code. Illumination shall be provided within all fire sprinkler and fire alarm control rooms, and in the immediate vicinity of all equipment not provided within a dedicated room, in accordance with section 1006.1.”

Alternative Automatic Fire-Extinguishing Systems - Section 904.3.5 Monitoring.

Insert: “...The building fire alarm system shall be supervised as required in 903.4.1 as amended above. When a fire alarm system is not provided within the building, any provided required alternative fire extinguishing system shall be monitored as required in 903.4 .1 as amended above.”

Standpipe Systems - Section 905.3.1 Building Height.

Delete: “...30 feet...” two locations.

Insert: “...18 feet...” two locations.

Standpipe Systems - Section 905.4 Location of Class I Standpipe Hose Connection.

Delete: Current section verbiage.

Insert: “Class I standpipe hose connections, consisting of a 2 1/2 inch valve and connection with a 2 1/2 inch by 1 1/2 inch reducing cap, shall be provided in all of the following locations:”

Fire Alarm and Detection Systems - Section 907.1.4 Secondary Power Supply.

Insert: “907.1.4 Secondary Power Supply. All fire alarm control equipment shall be provided with 60-hours of secondary power supply.”

Fire Alarm and Detection Systems - Section 907.1.5 Duct Smoke Detection.

Insert: “907.1.5 Duct Smoke Detection. Duct smoke detection provided or required by this, or other applicable codes, shall receive their power directly from an initiating device circuit or signal line circuit from the building fire alarm control unit when one is provided. Duct smoke detectors shall be installed in accordance with the manufacturer's instructions and shall be located within the building space in ambient conditions consistent with the listing of the duct detector.

Duct detectors shall be provided with remote alarm indicators and test switches located as directed by the Woodstock Fire/Rescue District.”

Fire Alarm and Detection Systems - Section 907.1.6 Automatic Fire Alarm System.

Insert: “907.1.6 Automatic Fire Alarm System. Where an automatic fire alarm system is required, detection shall be provided in accordance with NFPA 72 throughout all occupiable spaces within the building, and those areas required by other codes or standards.”

Fire Alarm and Detection Systems - Sections 907.2.1 Group A, 907.2.2 Group B, and 907.2.4 Group F.

Delete: Exceptions.

Fire Alarm and Detection Systems - Section 907.2.3 Group E.

Delete: Exceptions 3 and 4.

Fire Alarm and Detection Systems - 907.2.7 Group M.

Delete: Exception 2.

Fire Alarm and Detection Systems - Section 907.2.8.1 Group R-1 Manual Fire Alarm System.

Delete: Exception 2.

Fire Alarm and Detection Systems - Section 907.2.9 Group R-2.

Item 1.: Delete: “...three...”.
Insert: “...two ...”.

Item 3.: Delete.

Fire Alarm and Detection Systems - Section 907.6.3.1 Fire Alarm Annunciators.

Delete: Current section verbiage.

Insert: “907.6.3.1 Fire Alarm Annunciators. When the main fire alarm control equipment is not located at the entrance to the building used by the fire district, a remote annunciator, compatible with the fire alarm control unit, shall be provided in a location approved by the Fire District.

Fire alarm annunciators shall have the capability, when activated by the fire district with the use of a key, to provide the following functions:

1. Alarm acknowledgment.
2. Alarm silence.

3. Alarm reset.”

Annunciation at Multi-Tenant Buildings. Annunciation from multiple tenant building shall be provided when a fire alarm control unit supervises signals from multiple tenant spaces or dwelling unit buildings, each with their own individual entrance, in a one-story building, the following requirements shall apply:

1. Each tenant space, or dwelling unit entrance, shall be provided with an exterior mounted, weatherproof, clear or nominal white lens, 75 cd strobe light over the main entrance to the space.
2. Tenant space, or dwelling unit common area, initiating devices and notification appliances shall be zoned separately by the fire alarm control unit.
3. In buildings provided with an automatic sprinkler system, water-flow activation in a specific tenant space, or dwelling unit area, shall report as a water-flow activation from the space.
4. Exception: Area detection throughout the tenant space may be substituted for item 3 if the area detection reports an activation from the space. The exception does not apply to dwelling unit buildings.
5. Upon activation of an initiating device, with the exception of a water-flow device, within a tenant space or dwelling unit common area, the notification appliances within the space, and the exterior strobe shall activate for the space.
6. Upon the activation of a water-flow device in any tenant space, dwelling unit area, or the main water-flow device if provided, all interior and exterior notification appliances shall activate.”

Fire Alarm and Detection Systems - Section 907.6.4 Zones.

Delete: Current section verbiage but maintain the exception.

Insert: “For conventional (zone) fire alarm control panels, each floor of a building shall be zoned separately, and each type of device shall be zoned separately on each floor. A zone shall not exceed 22,500 square feet. The length of any zone shall not exceed 300-feet in any direction.

For addressable fire alarm control units, point identification shall be provided for each initiating device shall be addressed separately except that like supervisory devices, with the exception of fire pump monitoring, may be on a single identification address if located within the same room or space subject to the approval of the fire code official.

Each duct smoke detector shall be installed on its own zone or address.”

Fire Alarm and Detection Systems - Section 907.6.6 Monitoring.

Delete: Current section verbiage.

Insert: “Where a fire alarm system is required by this chapter, the system shall be monitored in accordance with 903.4.1 as amended.”

Fire Department Connections - Section 912.3 Hose Threads.

Insert: “All required fire department connections shall be provided with two- 2 1/2 inch connections with NST threads.”

Fire Department Connections - Section 912.7 Fire Hydrant Location.

Insert: “A fire hydrant, on a 6-inch (minimum size) distribution water main served by the municipal water system, shall be located within 100 feet of the fire department connection in a location approved by the Woodstock fire/rescue district.”

Doors, Gates and Turnstiles - 1010.2.4 Locks and Latches.

Item 2.: Delete.

Accessibility - Chapter 11.

Delete: Chapter 11 and any reference to accessibility within the International Building Code. All accessibility references shall be deferred to the Illinois Accessibility Code (current version).

Flood Loads - Section 1612.3 Establishment of Flood Hazard Areas.

Insert (seventh line): “Woodstock Fire/Rescue District, McHenry County, Illinois”

Insert (seventh line): “6/11/1982”

Shallow Foundations and Deep Foundations - Section 1809.12 Timber Footings and 1810.3.2.4 Timber.

Delete: All sections.

General Construction Requirements - Section 2304.14 Fire-Resistance Rating.

Insert: “2304.14 Fire-Resistance Rating. Where conventional light-frame wood construction, prefabricated wood- I-joist, structural composite lumber, structural glue-laminated timber, or similar structural wood components are utilized for floor construction, such construction shall be afforded a fire-resistance rating of not less than 1 hour.

Exception: Where the underside of the floor construction is protected with an approved fire

sprinkler system in accordance with section 903.3.1.1 or 903.3.1.2 the fire-resistance rating is not required.”

General - Section 2701.1 Scope.

Delete: “...provisions of the ICC electrical code.”

Insert: “...provisions of the National Electrical Code (the edition as adopted by the City of Woodstock.”

General - Section 2901.1 Scope.

Delete: “...the international plumbing code...”.

Insert: “...the Illinois State Plumbing Code, current edition...”.

Hoistway Enclosures - Section 3002.4 Elevator Car to Accommodate Ambulance Stretcher.

Delete: “Where elevators are provided in buildings four or more stories above grade or four or more stories below grade...”.

Insert: “Where a building is provided with an elevator, or a building exceeds two stories above grade, or a building exceeds two stories below grade...”.

Elevators and Conveying Systems - Section 3009 Periodic Tests and Inspections.

Insert: “3009.1 Required. Acceptance tests and/or inspections shall be provided on all equipment covered by chapter 30 as follows:

1. On all new, relocated and altered equipment subject to the provisions of this chapter.
2. Annually on all existing equipment.”

Insert: “3009.2 Test and Inspection Requirements. The minimum requirements for the inspection and test of the equipment subject to this chapter shall conform to the following:

1. Elevators, dumbwaiters and escalators shall be inspected and tested in accordance with ASME A17.1 listed in chapter 35.
2. Freight lifts and amusement devices shall be inspected and tested to assure the load capacity and safe operation of the equipment. The tests shall cover all operating protectives and safety devices, structural adequacy of the supports, and anchorage to floors, walls, ceilings and foundations.
3. Manlifts shall be inspected and tested in accordance with ASME A90.1 listed in chapter 35.
4. Miscellaneous hoisting and elevating equipment shall be subjected to tests and inspections as required by the code official to ensure safe operation.
5. Conveyors and related equipment shall be inspected and tested in accordance with ASME B20.1 listed in chapter 35.”

Insert: “3009.3 Fees. All fees for plan review, acceptance testing and annual inspections of equipment subject to this chapter shall be borne by the building owner subject to the fee schedule approved by the Woodstock Fire/Rescue District, McHenry County, Illinois.”

Insert: “3009.4 Certificate of Compliance. A certificate of compliance will be prepared by the Woodstock Fire/Rescue District upon the satisfactory inspection or test for all equipment subject to this chapter. The owner or lessee of the equipment shall post the certificate in a conspicuous place or shall indicate where the certificate is located for viewing.”

Chapter 35 Reference Standards.

The following referenced standards are hereby amended by using the edition indicated or the most current edition:

NFPA 11: 2016	NFPA 31: 2016	NFPA 111: 2016
NFPA 12: 2015	NFPA 32: 2016	NFPA 211: 2016
NFPA 12A: 2015	NFPA 40: 2016	NFPA 265: 2015
NFPA 13: 2016	NFPA 72: 2016	NFPA 276: 2015
NFPA 13D: 2016	NFPA 80: 2016	NFPA 409: 2016
NFPA 13R: 2016	NFPA 85: 2015	NFPA 418: 2016
NFPA 14: 2016	NFPA 105: 2016	NFPA 701: 2015
NFPA 20: 2016	NFPA 110: 2016	NFPA 1124: 2013
NFPA 30: 2015		

SECTION 4: The provisions included in this ordinance shall have an effective date of May 1, 2023.

SECTION 5: Any ordinances or parts of ordinances that are in conflict or inconsistent with any of the provisions of this ordinance are hereby repealed to the extent that they conflict.

SECTION 6: The invalidation of any section, part, provision, term or phrase of this Ordinance shall not affect the validity of the remaining sections of this Ordinance.

SECTION 7: This Ordinance shall be in full force and effect from and after its passage, approval, and publication. The Secretary is hereby directed to publish this Ordinance as required by law.

PASSED by the Board of Trustees of the Woodstock Fire/Rescue District, McHenry County, Illinois, and approved this 23 day of march, 2023.

AYES: 5
 NAYES: 0
 ABSENT: 0

APPROVED: Frederick Spitzer
President, Frederick Spitzer

ATTEST: Robert A. Kristensen
Secretary, Robert A. Kristensen

Z:\W\WoodstockFire\Ordinances\InternationalBuildingCode2021.docx

CERTIFICATION


I, ROBERT A. KRISTENSEN, do hereby certify that I am the duly appointed, acting and qualified Secretary of the Woodstock Fire/Rescue District, Woodstock, McHenry County, Illinois, and that as such Secretary, I am the keeper of the records and minutes and proceedings of the President and Board of Trustees of said Woodstock Fire/Rescue District.

I do hereby further certify that at a regular meeting of the President and Board of Trustees of the Woodstock Fire/Rescue District, held on the 23 day of March, 2023, the foregoing Ordinance entitled, **An Ordinance Repealing Ordinance Number 204 and Adopting the 2021 Edition of the International Building Code, with Amendments, in the Woodstock Fire/Rescue District, McHenry County, Illinois**, was duly passed by the President and Board of Trustees of the Woodstock Fire/Rescue District.

The pamphlet form of Ordinance No. 239, including the Ordinance and a cover sheet thereof, was prepared, and a copy of such Ordinance was available from the Secretary, commencing on the 23 day of March, 2023, and will continue for at least 10 days thereafter. Copies of such Ordinance are also available for public inspection upon request in the office of the Woodstock Fire/Rescue District.

I do further certify that the original, of which the attached is a true and correct copy, is entrusted to me as the Secretary of said Woodstock Fire/Rescue District for safekeeping, and that I am the lawful custodian and keeper of the same.

Given under my hand and the official seal of the Woodstock Fire/Rescue District this 23 day of March, 2023.



Robert A. Kristensen, Secretary
Woodstock Fire/Rescue District,
Woodstock, McHenry County, Illinois

(SEAL)

